



# City of Smyrna

## Issue Sheet

A Max Bacon  
City Hall  
2800 King Street  
Smyrna, GA 30080

File Number: ATH2023-15

---

**Agenda Date:** 6/5/2023

**In Control:** City Council

**File Type:** Authorization

**Agenda Section:**

**Agenda Number:** G.

Formal Business

**Department:** Public Works

**Agenda Title:**

This is a request from water distribution for the approval for emergency sewer main line repair of 18" sewer main line located rear of 1097 Queens Gate Drive from current pipe lining contractor (UAM) Utility Asset Management Group in the amount of \$104,077.00 and authorize mayor to execute all related documents.

***Ward 7***

.

**ISSUE AND BACKGROUND:**

On or about 12:20pm on May 24, 2023. The City of Smyrna was made aware of a broken leaking sanitary sewer line overflow. It appears there was a total discharge amount upon arrival was about 23 gallons, the spill location is inside a concrete creek crossing located on outfall located on a property of City of Smyrna easement located Behind 1095 and 1097 Queens Gate Drive. Nick jack Creek tributary waters were affected. The City of Smyrna took corrective action by contacting emergency lining crew to have sewer main lined immediately, also cleaning, servicing, videoing both upstream and downstream and Neutralizing soils in affected area of this manhole has taken place. Signs will be posted at spill site to notify.

**RECOMMENDATION / REQUESTED ACTION:**

This is a request from water distribution for the approval for emergency sewer main line repair of 18" sewer main line located rear of 1097 Queens Gate Drive from current pipe lining contractor (UAM) Utility Asset Management Group in the amount of \$104,077.00 and authorize mayor to execute all related documents.